



MESS ID: **06601** Reported: 4/15/2004 at 11:15 AM  
Problem Description: Pollutant: VOC Equipment: Ecoat incinerator

The e-coat incinerator went off line on 4/14 @ 4:00 pm. Emergency repairs were initiated and the root cause was found to be electrical control component related. The board was replaced and the unit was brought back on line @ 10:30 pm.

On 4/29/04 @ 2:31 received faxed written report for malfunction of control equipment(E-coat Incinerator emissions unit - U010) at the Ford-Louisville Assembly Plant on April 14th and ending April 15th 2004. Corrections made to dates and times.

Started: 4/14/2004 at 12:42 PM Stopped: 4/15/2004 at 03:52 AM

---

1 Problem reported by plant 0072

---

### Plant: 0148 Lou Med Center Steam Plant, 235 Abraham Flexner Way

MESS ID: **06605** Reported: at : AM  
Problem Description: Pollutant: PART. OPACITY Equipment: Unit 4 Boiler

Will fire unit 4 boiler on 4-21-04. It will replace Unit 6 boiler, which is due for spring inspection & maintenance. Some smoking may occur upon start up.

Started: 4/21/2004 at 05:00 AM Stopped: 4/21/2004 at 08:00 AM

---

MESS ID: **06609** Reported: 4/26/2004 at 08:30 AM  
Problem Description: Pollutant: PART. OPACITY Equipment: Baghouse

Will shut down the baghouse for 1 hour on Monday, 4-26-04. A trial filter bag needs to be placed in the baghouse while it's out of service.

Started: 4/26/2004 at 09:00 AM Stopped: 4/26/2004 at 10:00 AM

---

2 Problems reported by plant 0148

---

### Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

MESS ID: **06603** Reported: 4/18/2004 at 12:00 AM  
Problem Description: Pollutant: PART. OPACITY Equipment: #4 Boiler

4 Boiler shutdown.

Started: 4/18/2004 at 12:00 AM Stopped: 4/18/2004 at 02:00 AM

---

MESS ID: **06608** Reported: 4/23/2004 at 01:05 AM  
Problem Description: Pollutant: PART. OPACITY Equipment: #4 Boiler

#4 boiler start up. Line out boiler and bring up to temperature.

Started: 4/23/2004 at 12:38 AM Stopped: 4/23/2004 at 07:30 AM

---

MESS ID: **06611** Reported: 4/27/2004 at 05:35 PM  
Problem Description: Pollutant: PART. OPACITY Equipment: Coal Boiler #6

Coal boiler #6 shut down.

Started: 4/27/2004 at 05:30 PM Stopped: 4/27/2004 at 06:45 PM

---

MESS ID: 06610

Reported: 4/29/2004 at 12:21 PM

**Problem Description:**

Pollutant: PART. OPACITY

Equipment: Boiler #6

Boiler #6 smoke particulate, Start up and line out boiler.

Started: 4/29/2004 at 10:25 AM

Stopped: 4/29/2004 at 12:20 PM

---

4 Problems reported by plant 1333

---

**Plant: 0115 Swift & Company, 1200 Story Ave**

MESS ID: 06602

Reported: 4/16/2004 at 04:20 PM

**Problem Description:**

Pollutant: PART. OPACITY

Equipment: Lower Scrubber

Pumps on the small scrubber quit pumping sometime between 2:00 & 3:00 p.m. We started our back up pump and everthing is ok.

Started: 4/16/2004 at 02:00 PM

Stopped: 4/16/2004 at 03:00 PM

---

1 Problem reported by plant 0115

---

**Plant: 0283 Zeon Chemicals L.P., 4100 Bells Ln**

MESS ID: 06613

Reported: 5/5/2004 at 06:53 AM

**Problem Description:**

Pollutant: VOC

Equipment: T.C.O.

The thermal catalytic oxidizer utilized for odor control on the PA charging system will be shut down for catalyst replacement from 8:00 a.m. until 4:00 p.m. on 5/5/04. No PA will be charged during this period. There will be no increased emissions or odors during this period. This activity is a normal maintenance activity for the T.C.O.

Started: 5/5/2004 at 08:00 AM

Stopped: 5/5/2004 at 04:00 PM

---

1 Problem reported by plant 0283

---