

Louisville Metro Air Pollution Control District
Malfunctions, Emergencies, Startups and Shutdowns
Received 6/8/2004 Through 7/7/2004

Plant: 0011 American Synthetic Rubber, 4500 Camp Ground Rd

Started: 7/2/2004 at 06:50 PM Stopped: 7/2/2004 at 07:15 PM MESS ID: 06647

Problem Description: Pollutant: PART. OPACITY Equipment: RTO

Temp. on RTO dropped off gradually & the RTO was taken off line, it was checked and put back on line. The mushroom damper may have been open during that time we are investigating.

Reported: 7/2/2004 at 07:34 PM STATUS: WORKING

1 Problem reported by plant 0011

Plant: 0026 Blue Grass Coop., Brown-Forman, 402 McLean Ave

Started: 6/22/2004 at 11:15 AM Stopped: 6/22/2004 at 01:10 PM MESS ID: 06646

Problem Description: Pollutant: PART. DUST Equipment: West Cyclone

West cyclone stopped up and had to shutdown all dust system and postpone production to clean and check out all dust systems.

Reported: 6/22/2004 at 01:14 PM STATUS: WORKING

1 Problem reported by plant 0026

Plant: 0028 Borden Chemical, Inc, 6200 Camp Ground Rd

Started: 6/8/2004 at 11:00 AM Stopped: 6/8/2004 at 01:30 PM MESS ID: 06637

Problem Description: Pollutant: PART. OPACITY Equipment: Gas Boiler

Plant start up.

Reported: 6/8/2004 at 03:00 PM STATUS: WORKING

1 Problem reported by plant 0028

Plant: 0808 DD Williamson & Company, Inc., 1901 Payne St

Started: 6/11/2004 at 06:00 AM Stopped: 6/28/2004 at 07:00 AM MESS ID: 06643

Problem Description: Pollutant: SO2 Equipment: Cooker

See attachment:

Reported: at : AM STATUS: WORKING

Started: 6/18/2004 at 07:00 AM Stopped: 6/28/2004 at 07:00 AM MESS ID: 06642

Problem Description: Pollutant: PART. OPACITY Equipment: Spray Dryer

See attachment:

Reported: 6/18/2004 at 12:30 PM STATUS: WORKING

2 Problems reported by plant 0808

Plant: 0072 Ford Motor Co, Lou Assy Plant, 2000 Fern Valley Rd

Plant: 0072 Ford Motor Co, Lou Assy Plant, 2000 Fern Valley Rd

Started: 6/9/2004 at 06:00 AM Stopped: 6/9/2004 at 11:20 AM MESS ID: 06638

Problem Description: Pollutant: VOC Equipment: Zone 5 clearcoat

The zone 5 clear coat carbon absorption system is currently off line due to a sprinkler system malfunction. Emergency repairs have been initiated and no emission limitation is expected as a result of this malfunction.

Reported: 6/9/2004 at 10:50 AM STATUS: WORKING

1 Problem reported by plant 0072

Plant: 0148 Lou Med Center Steam Plant, 235 Abraham Flexner Way

Started: 6/16/2004 at 07:00 AM Stopped: 6/16/2004 at 09:00 AM MESS ID: 06641

Problem Description: Pollutant: PART. OPACITY Equipment: Baghouse

Will shut down the baghouse on Wed., 6-16-04. The purpose of the shutdown is to remove a sample filter bag supplied from a new vendor.

Reported: at : AM STATUS: WORKING

1 Problem reported by plant 0148

Plant: 0149 Metro Sewer Dist, Morris Forman, 4522 Algonquin Pkwy

Started: 7/7/2004 at 04:00 AM Stopped: 7/8/2004 at 08:00 AM MESS ID: 06648

Problem Description: Pollutant: ODOR Equipment: #2 Anaerobic Digester

Gap in digester line, leaked some digester gas at hole near flange. Repaired.

Reported: at : AM STATUS: WORKING

1 Problem reported by plant 0149

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

Started: 6/18/2004 at 04:40 PM Stopped: 6/18/2004 at 08:20 PM MESS ID: 06645

Problem Description: Pollutant: PART. OPACITY Equipment: #6 Boiler

#6 boiler startup.

Reported: at : AM STATUS: WORKING

Started: 6/18/2004 at 10:05 AM Stopped: 6/18/2004 at 01:15 PM MESS ID: 06644

Problem Description: Pollutant: PART. DUST Equipment: Ash Silo

Open door on ash silo to unplug.

Reported: at : AM STATUS: WORKING

2 Problems reported by plant 1333
