

Louisville Metro Air Pollution Control District
Malfunctions, Emergencies, Startups and Shutdowns
11/11/2004 Through 12/6/2004

Plant: 0650 Gene Snyder Building, 600 W Broadway

Started: 11/24/2004 at 08:00 AM Stopped: 11/24/2004 at 11:59 PM MESS ID: 06696

Problem Description: Pollutant: PART. OPACITY Equipment: Boilers

Firing boilers using back up fuel supply for operational testing & combustion analysis. (Wil be fired using #2 diesel)

Reported: 11/24/2004 at 08:00 AM STATUS: WORKING

1 Problem reported by plant 0650

Plant: 0148 Lou Med Center Steam Plant, 235 Abraham Flexner Way

Started: 11/16/2004 at 05:00 AM Stopped: 11/16/2004 at 08:00 AM MESS ID: 06694

Problem Description: Pollutant: PART. OPACITY Equipment: Unit 5 Boiler

The MCSP will fire Unit 5 on Tuesday, 11-16-04. It will replace Unit 4 boiler which needs routine inspection. Some smoking may occur at start up.

Reported: at : AM STATUS: WORKING

1 Problem reported by plant 0148

Plant: 0532 Outer Loop Recycling & Disp, 2673 Outer Loop

Started: 11/12/2004 at 08:00 AM Stopped: 11/12/2004 at 02:00 PM MESS ID: 06693

Problem Description: Pollutant: PART. OPACITY Equipment: Flare I

Flare one will be shutdown for Unit 7 booster blower tie in on 11-12-04 at 0800 hrs. till about 1400 hrs.

Reported: at : AM STATUS: WORKING

1 Problem reported by plant 0532

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

Started: 11/21/2004 at 07:30 AM Stopped: 11/21/2004 at 07:30 AM MESS ID: 06698

Problem Description: Pollutant: PART. OPACITY Equipment: Dust Collector

Dust collector door leak.

Reported: 11/21/2004 at 10:05 AM STATUS: WORKING

Started: 11/23/2004 at 02:00 PM Stopped: 11/23/2004 at 02:00 PM MESS ID: 06695

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler #4

Boiler #4 Start Up. Smoke particulates >20%. Start up boiler and bring up to temperature

Reported: 11/23/2004 at 01:58 AM STATUS: WORKING

2 Problems reported by plant 1333
