

Louisville Metro Air Pollution Control District
Malfunctions, Emergencies, Startups and Shutdowns
6/8/2005 Through 7/11/2005

Plant: 0243 Heaven Hill Distilleries, Inc., 1701 W Breckinridge St

Started: 7/8/2005 at 08:15 AM Stopped: at : AM MESS ID: 06767

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler

Received phone call from Kevin Burke, calling the malfunction in for Tim Latondress. Boiler back up smoking on low end, will get it corrected.

Reported: 7/8/2005 at 08:45 AM STATUS: WORKING

1 Problem reported by plant 0243

Plant: 0149 Metro Sewer Dist, Morris Forman, 4522 Algonquin Pkwy

Started: 6/27/2005 at 11:00 AM Stopped: 6/28/2005 at 12:00 PM MESS ID: 06764

Problem Description: Pollutant: ODOR Equipment: Biotower Odor Contro

Overload conditions in the biotower scrubber #2 due to high ambient temperatures and solids overloading in the primary process result in 30 ppm H2S in scrubber exhaust. Detectable off plant site according to inspector Sam Bate. Notified maintenance and operations personnel to inspect and look for malfunction. Expect to have #1 scrubber back in service by 6/28 which should eliminate problem by reducing loading to #2 unit.

Reported: 6/27/2005 at 02:00 PM STATUS: WORKING

1 Problem reported by plant 0149

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

Started: 6/11/2005 at 04:15 PM Stopped: 6/11/2005 at 07:50 PM MESS ID: 06763

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler 6

Boiler 6 start up.
Fire boiler and line out.

Reported: 6/11/2005 at 04:10 PM STATUS: WORKING

Started: 6/29/2005 at 05:57 PM Stopped: 6/29/2005 at 09:35 PM MESS ID: 06766

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler #6

Boiler #6 start up. Line out boiler and bring up to temperature.

Reported: 6/29/2005 at 05:55 PM STATUS: WORKING

2 Problems reported by plant 1333
