

Louisville Metro Air Pollution Control District
Excess Emission Reports
9/13/2005 Through 10/12/2005

Plant: 0028 Borden Chemical, Inc, 6200 Camp Ground Rd

Started: 9/14/2005 at 09:00 AM Stopped: 9/14/2005 at 10:15 AM MESS ID: **06793**

Problem Description: Pollutant: PART. OPACITY Equipment: Stack Gas Boiler

Plant start up.

Reported: 9/14/2005 at 10:15 AM STATUS: WORKING

Started: 9/26/2005 at 12:00 AM Stopped: at : AM MESS ID: **06799**

Problem Description: Pollutant: PART. OPACITY Equipment: Unit

Unit start up.

Reported: 9/26/2005 at 04:00 PM STATUS: WORKING

Started: 9/27/2005 at 11:30 AM Stopped: 9/27/2005 at 03:30 PM MESS ID: **06798**

Problem Description: Pollutant: PART. OPACITY Equipment: Emission Control Dev

Start up after fixing emission control device.

Reported: 9/27/2005 at 11:30 AM STATUS: WORKING

3 Problems reported by plant 0028

Plant: 0620 John Conti Coffee, 4023 Bardstown Rd

Started: 10/3/2005 at 06:30 AM Stopped: 10/3/2005 at 01:30 PM MESS ID: **06801**

Problem Description: Pollutant: PART. OPACITY Equipment: Burner

Rec'd email, 10-3-05, attached; Trouble with a burner after being turned on. Started about 6:30 a.m. Shut it down and cleaned it out. Everything appears to be working.

Reported: 10/3/2005 at 01:30 PM STATUS: WORKING

1 Problem reported by plant 0620

Plant: 0126 Lou. Gas & Elec., Cane Run, 5252 Cane Run Rd

Started: 9/19/2005 at 09:00 AM Stopped: 9/19/2005 at 10:00 AM MESS ID: **06795**

Problem Description: Pollutant: SO2 Equipment: SO2 Scrubber

ID # CR6091920050915, see attached email.

Reported: 9/19/2005 at 10:30 PM STATUS: WORKING

Started: 9/21/2005 at 08:00 AM Stopped: 9/21/2005 at 10:00 AM MESS ID: **06797**

Problem Description: Pollutant: SO2 Equipment: SDRS

Email re: malfunction ID # CR6092120050830, see attached.

Reported: 9/21/2005 at 08:30 AM STATUS: WORKING

Started: 9/27/2005 at 11:00 PM Stopped: 9/27/2005 at 12:00 AM MESS ID: **06802**

Problem Description: Pollutant: SO2 Equipment: Unit 6 Scrubber

Received email, 10-6-05; ID #CR6100520051520.

Boiler tube leak/trip. Event was not reported because CEM data was suspect at the time, but has now been verified.

Reported: 10/5/2005 at 03:20 PM STATUS: WORKING

Plant: 0126 Lou. Gas & Elec., Cane Run, 5252 Cane Run Rd

3 Problems reported by plant 0126

Plant: 0127 Lou. Gas & Elec., Mill Creek, 14660 Dixie Hwy

Started: 9/21/2005 at 05:00 PM Stopped: 9/21/2005 at 07:00 PM MESS ID: 06796

Problem Description: Pollutant: SO2 Equipment: MC-4

Received email @ 5:38 pm re: Initial notification of SO2 removal @ 5:00 pm. Excess emissions are likely to occur: 2 hours, inadequate reactant supply, corrective action being taken.

Receive email re: Excess emission completion report 9/21/05 @ 7:00 pm, by James O Autry Sr., SO2 reactant supply.

Reported: 9/21/2005 at 07:00 PM STATUS: WORKING

1 Problem reported by plant 0127

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

Started: 10/1/2005 at 11:00 PM Stopped: 10/2/2005 at 02:15 AM MESS ID: 06800

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler #6

Boiler #6 start up. Line out & bring up to temp.

Reported: 10/1/2005 at 11:00 PM STATUS: WORKING

Started: 10/7/2005 at 09:15 PM Stopped: 10/7/2005 at 11:30 PM MESS ID: 06803

Problem Description: Pollutant: PART. OPACITY Equipment: Baghouse #4 Boiler

Bypass baghouse on #4 boiler. Bringing baghouse on line.

Reported: 10/7/2005 at 09:30 PM STATUS: WORKING

Started: 10/8/2005 at 01:45 AM Stopped: 10/8/2005 at 04:05 AM MESS ID: 06804

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler 6

Boiler 6 start up.

Reported: 10/8/2005 at 01:30 AM STATUS: WORKING

3 Problems reported by plant 1333
