

Louisville Metro Air Pollution Control District
Excess Emission Reports
11/4/2005 Through 12/5/2005

Plant: 0011 American Synthetic Rubber, 4500 Camp Ground Rd

Started: 11/11/2005 at 12:15 AM Stopped: at : AM Report ID: **06819**

Problem Description: Pollutant: PART. OPACITY Equipment: Baghouse

Baghouse problem. Failing baghouse module was isolated.

Reported: 11/11/2005 at 12:15 AM STATUS: WORKING

Started: 11/16/2005 at 04:50 PM Stopped: 11/16/2005 at 04:50 PM Report ID: **06822**

Problem Description: Pollutant: SO2 Equipment: Spray Reactor

11/16/15, 8:11 pm, received malfunction fax re: shutdown, scheduled replacement of spray reactor disk drive atomizer. Returned to service @ 4 pm, SO2.

Reported: 11/16/2005 at 08:11 PM STATUS: WORKING

Started: 11/25/2005 at 09:00 AM Stopped: 11/25/2005 at 10:00 AM Report ID: **06828**

Problem Description: Pollutant: PART. OPACITY Equipment: #9 Baghouse

Sandblasting in #9 baghouse causing excess opacity.

Baghouses were being isolated to determine which if any were compromised.

Reported: 11/25/2005 at 12:54 PM STATUS: WORKING

Started: 11/28/2005 at 02:54 PM Stopped: 11/28/2005 at 03:18 PM Report ID: **06829**

Problem Description: Pollutant: PART. OPACITY Equipment: Baghouse

Baghouse problems.

Baghouses are being isolated to determine which if any were compromised.

Reported: 11/28/2005 at 06:53 PM STATUS: WORKING

Started: 11/30/2005 at 08:30 AM Stopped: 11/30/2005 at 09:00 AM Report ID: **06830**

Problem Description: Pollutant: VOC Equipment: Unknown

Chris Manion of ASRC called regarding Chemical Spill, Poly Butadiene, Toluene Rubber Solution. Incident occurred at 8:30 and contained immediately, ended approximately 9:00 am.

Reported: 11/30/2005 at 09:00 AM STATUS: WORKING

5 Problems reported by plant 0011

Plant: 0028 Borden Chemical, Inc, 6200 Camp Ground Rd

Started: 11/6/2005 at 06:30 PM Stopped: at : AM Report ID: **06816**

Problem Description: Pollutant: PART. OPACITY Equipment: Gas Boiler

Unit shut down.

Reported: 11/6/2005 at 08:36 PM STATUS: WORKING

Started: 11/8/2005 at 09:00 AM Stopped: 11/8/2005 at 11:30 AM Report ID: **06817**

Problem Description: Pollutant: PART. OPACITY Equipment: Stack Gas Boiler

Starting plant up.

Reported: 11/8/2005 at 08:02 AM STATUS: WORKING

Plant: 0028 Borden Chemical, Inc, 6200 Camp Ground Rd

Started: 11/14/2005 at 11:00 PM Stopped: 11/14/2005 at 12:00 AM Report ID: **06820**

Problem Description: Pollutant: PART. OPACITY Equipment: Gas Boiler

Storm related.

Reported: 11/14/2005 at 11:52 AM STATUS: WORKING

Started: 11/16/2005 at 06:00 AM Stopped: 11/16/2005 at 06:15 AM Report ID: **06824**

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler

Unit shutdown maintenance & low methanol.

Received ltr; re: equipment shutdown notification, incident date 11-16-05, completion time, 6:15.

Reported: 11/16/2005 at 06:00 AM STATUS: WORKING

Started: 11/19/2005 at 07:30 AM Stopped: 11/19/2005 at 10:30 AM Report ID: **06826**

Problem Description: Pollutant: PART. OPACITY Equipment: Gas Boiler

Unit start up.

Received ltr; re: equipment start up/ shutdown notification, incident date 11-19-05.

Reported: 11/19/2005 at 11:00 AM STATUS: WORKING

Started: 11/20/2005 at 07:00 AM Stopped: 11/20/2005 at 10:00 AM Report ID: **06827**

Problem Description: Pollutant: PART. OPACITY Equipment: Gas Boiler

Start up unit.

Reported: 11/20/2005 at 09:40 AM STATUS: WORKING

6 Problems reported by plant 0028

Plant: 0062 E I duPont de Nemours & Co, 4200 Camp Ground Rd

Started: 11/18/2005 at 10:36 AM Stopped: at : AM Report ID: **06823**

Problem Description: Pollutant: SO2 Equipment: Pipeline

Rec'd call from Cheryl Fisher regarding release occurring on Rohm & Haas property. Release quantity unknown. Called 911 & response center. Pipeline from Citgo to DuPont plant. Chloroform.

Reported: 11/18/2005 at 10:36 AM STATUS: WORKING

1 Problem reported by plant 0062

Plant: 0127 Lou. Gas & Elec., Mill Creek, 14660 Dixie Hwy

Started: 11/29/2005 at 12:00 AM Stopped: 11/29/2005 at 01:00 PM Report ID: **06831**

Problem Description: Pollutant: SO2 Equipment: SO2

Email, ID # MC3 11-29-05 1200; PH probe & instrumentation malfunction.

Reported: 11/30/2005 at 10:00 AM STATUS: WORKING

1 Problem reported by plant 0127

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

Started: 11/18/2005 at 06:20 PM Stopped: 11/18/2005 at 09:20 PM Report ID: **06825**

Problem Description: Pollutant: PART. OPACITY Equipment: Boiler #4

Boiler #4 start up.

Reported: 11/18/2005 at 06:20 PM STATUS: WORKING

Plant: 1333 Oxy Vinyls LP, 4014 Bells Lane

1 Problem reported by plant 1333

Plant: 0852 U of L, Belknap Campus, 2127 S Floyd St

Started: 11/17/2005 at 10:37 AM Stopped: at : AM Report ID: **06821**
Problem Description: Pollutant: PART. OPACITY Equipment: Coal Fire Boiler #2

U of L called to advise APCD of Starting up Coal Fire Boiler #2. Will call back with all clear.

Reported: 11/17/2005 at 10:37 AM STATUS: WORKING

1 Problem reported by plant 0852
